



SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Scott Walker, Governor
Paul F. Jadin, Secretary

February 16, 2011

DACCO INC. OF WISCONSIN
DICK HARTENSTEIN
2697 HWY P
RICHFIELD WI 53076

FOREST RIVER PREMIERE STRUCTURES
DAREN LEHMAN
2501 OAKLAND AVE
ELKHART IN 45517

Re: Description: PREFABRICATED PLUMBING SYSTEM
Manufacturer: FOREST RIVER PREMIERE STRUCTURES
Product Name: DACCO MODEL #13
Model Number(s): NA
Product File No: 20110049

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of May 2016.

This approval is contingent upon compliance with the following stipulation(s):

- The flowing water supply pressure at the point(s) of connection must be at least 31 psig.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.

This approval supersedes the approval issued on May 5, 2006 under product file number 20060200.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20060200.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson
Plumbing Product Reviewer
Phone: 608-266-6742
Fax: 608-267-9566
E-mail: jerry.thompson@wi.gov